



10901 Pump House Road
 Annapolis Junction, MD 20701-1125
 Balt.(410) 792-4230 • Wash.(301) 953-9370
 Fax: (301) 490-7156

**Mechanical Equipment
 Sales & Service**

HYDRONIC PUMP START UP REQUEST

Return This Form via Email MDSERVICESUPPORT@CUMMINS-WAGNER.COM or Fax# 301-490-9518

Contractor:					C-W Sales Engineer:				
Project Name:									
Address:				City:			State:		
Jobsite Contact:				Jobsite Contact Number:					
Project Manager:				Project Manager Phone:			Office:		
							Cell:		

	Yes	No
1. Confirm all Pumps are piped and mounted correctly.		
2. Check that the suction or discharge lines are not forced into position.		
3. Check that there is a strong, rigid support for the suction and discharge lines.		
4. Confirm all Pump bases are properly secured and grouted to concrete foundation.		
5. Inspect Area around pump for recommended service clearance.		
6. Pipe union/flanges located to allow pump removal.		
7. If isolation is used check that flexible piping is used on both the suction and discharge sides of the pump.		
8. Pipes are supported independently of the pump.		
9. Insulation installed allows for service.		
10. Maintenance access acceptable for unit and components per manufacturer's instructions and/or specifications.		
11. All Electrical Connections are completely wired and grounded. Electrical match pump's nameplate specifications. (Incorrect voltage can cause fire, damage motor and voids warranty.)		
12. Leg Disconnect is installed / wired near pump.		

Booster Skid Information

Booster Tag:								
Make:	Bell & Gossett			Model Number:				
GPM:		TDH:		Serial Number:				
Voltage/Phase:		HP:		Horsepower:			RPM:	
Insulation Class:	B	F	H	Premium Eff. Motor:	Yes		No	
Motor Enclosure:	ODPE		TEFC	Booster Location:	Inside		Outside	

Booster Skid Information

Booster Tag:								
Make:	Bell & Gossett			Model Number:				
GPM:		TDH:		Serial Number:				
Voltage/Phase:		HP:		Horsepower:			RPM:	
Insulation Class:	B	F	H	Premium Eff. Motor:	Yes		No	
Motor Enclosure:	ODPE		TEFC	Booster Location:	Inside		Outside	

Authorized Signature: _____

Date: _____

Printed Name: _____

Title: _____

I hereby authorize request for Start-Up. I acknowledge that all equipment that is deemed not ready for requested service is subject to additional cost to complete start-up and/or alignment.

www.cummins-wagner.com

Ashland, VA • Virginia Beach, VA • Annapolis Junction, MD • Warrenton, VA • Winchester, VA • Elizabethtown, PA • Williamsport, PA
 (804) 550-3311 (800) 550-3373 (301) 490-9007 (540) 341-7794 (540) 868-1829 (717) 367-8294 (717) 321-1188